


RFC 430 ETH-IB

Order No.: 2730190



<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2730190>

Remote Field Controller with 1x10/100 Ethernet, INTERBUS-Master, IP20 degree of protection, pluggable parameterization memory (MC FLASH)

| Commercial data | |
|--------------------------|--|
| GTIN (EAN) |  4 017918 189235 |
| Note | Made-to-order |
| sales group | K220 |
| Pack | 1 pcs. |
| Customs tariff | 85371091 |
| Catalog page information | Page 30 (AX-2009) |

Product notes

WEEE/RoHS-compliant since:
12/07/2009



<http://www.download.phoenixcontact.com>
Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

Product description

Remote Field Controllers for Ethernet networks

When it comes to distributed, modular automation, Remote Field Controllers (RFC) with IEC 61131 control system intelligence and network connection are the ideal solution. Remote Field Controllers are compact, industrial PCs that provide networked, PC-based control performance on site with DIN rail mounting.

Integrated Ethernet connection

The integrated Ethernet network connection (via twisted pair) ensures Ethernet connectivity, an increasingly important factor.

The "DIN rail PCs" can be reached via Ethernet and TCP/IP by means of remote operation. Programming, operation, and visualization via the network enable innovative and cost-effective automation solutions.

When using the INTERBUS OPC server, standardized coupling with various visualization packages is also available via Ethernet.

IEC 61131 controller performance

Remote Field Controllers are based on the international PC/104 standard for embedded PC systems. All Remote Field Controllers are seamlessly configured and programmed according to IEC 61131 using the PC WORX automation software. PC WORX can be used locally on the serial interface or via the network (Ethernet).

The powerful processor can be programmed in all five IEC 61131 programming languages and ensures quick control task processing.

Ethernet communication

The integrated communication functions of the RFC ... ETH-IB modules enable direct and time-effective data exchange via Ethernet. The Ethernet TCP/IP protocol is used for universal possibilities to communicate with Remote Field Controllers. The standardized transport protocol TCP/IP is known worldwide and is available for all computer architectures and operating systems.

In the Ethernet network data is available in a standardized format using the INTERBUS OPC server.

Using the TCP/IP Send and Receive communication blocks according to the IEC-61131-5 standard, information between two Remote Field Controllers, e.g. necessary coupling variables, can be exchanged via Ethernet. This enables distributed, modular automation solutions to be configured. Even time synchronization is possible via the Ethernet network.

Technical data

Mechanical design

| | |
|---|--|
| Format | 124 x 185 x 190 mm (W x H x D without fan and without key) |
| | 124 x 210 x 190 mm (W x H x D with fan and without key) |
| Height | 181 mm |
| Width | 122 mm |
| Depth | 182 mm |
| Weight | 1550 g |
| Note on weight specifications | Without fan module |
| Weight | 1700 g |
| Note on weight specifications | With fan module |
| Degree of protection | IP20 |
| Ambient temperature (operation) | 0 °C ... 55 °C (from 45°C only with fan module) |
| Ambient temperature (storage/transport) | -25 °C ... 70 °C |

Data interfaces

| | |
|--------------------|---|
| Interface | INTERBUS 2-wire remote bus |
| Type of connection | D-SUB-9 female connector |
| Interface | Parameterization/operation/diagnostics |
| Type of connection | RS-232-C, D-SUB connector, Ethernet 10/100 (RJ45) |
| Interface | Host system |
| Type of connection | Computer and control system, direct twisted pair connection (10Base-T/100Base-T) via RJ45 |
| Interface | Ethernet 10Base-T/100Base-TX |
| Type of connection | RJ45 female connector |
| Transmission speed | 10/100 MBit/s |

IEC 61131 runtime system

| | |
|----------------------------|---|
| Programming tool | PC WORX 2 PC WORX 3 |
| Processing speed | 0.1 ms (1 K mix instructions) (1 K bit instructions) |
| Data memory | 4 Mbyte |
| Retentive data memory | 96 kByte (NVRAM) |
| Number of data blocks | (depends on data memory) |
| Number of timers, counters | (depends on data memory) |
| Number of control tasks | 16 |
| Realtime clock | Integrated (battery backup) |

Power supply

| | |
|-----------------------------|--|
| Power supply connection | Screw terminal blocks, plug-in |
| Typical current consumption | 1.5 A |
| Supply voltage | 24 V DC |
| Supply voltage range | 20 V DC ... 30 V DC (including ripple) |
| Residual ripple | ±5% |

INTERBUS data

| | |
|--|--|
| Type | INTERBUS master |
| Number of devices with parameter channel (PCP) | max. 126 |
| Number of supported devices | 512 (of which 254 are remote bus devices/bus segments) |
| Number of I/O nodes | max. 8192 |
| Battery | Integrated (rechargeable battery buffered) |

| | |
|----------------------------|--------------------------|
| Number of control tasks | 16 |
| Number of timers, counters | (depends on data memory) |
| Number of data blocks | (depends on data memory) |
| Number of flags | 32618 ... 65236 |
| Data memory | 4 Mbyte |
| Retentive data memory | 96 kByte (NVRAM) |

Local diagnostics

| | |
|------------------------|------------------------|
| Monitored function | Higher-level network |
| Optical representation | Status display via LED |
| Name | LINK, TRAFFIC |

Certificates / Approvals



Certification CUL, UL

Accessories

| Item | Designation | Description |
|------------------------|------------------|---|
| Cable/conductor | | |
| 2806862 | IBS PRG CAB | Connection cable, to connect the controller boards to the PC (RS-232-C), length 3 m |
| General | | |
| 2730239 | RFC DUAL-FAN | Fan module for Remote Field Controllers RFC 430 ETH-IB / RFC 450 ETH-IB |
| 2737135 | SPARE KEYSSET | Spare key for the RFC 4xx ETH-IB. |
| Memory | | |
| 2729389 | IBS MC FLASH 2MB | Program and configuration memory, 2 Mbyte |
| 2729392 | IBS MC FLASH 4MB | Program and configuration memory, 4 Mbyte |
| Software | | |
| 2985945 | AX OPC SERVER | AX OPC SERVER, communication interface for OPC-capable visualization with PC WORX-based controls. |

| | | |
|---------|----------------------|---|
| 2985275 | PC WORX BASIC LIC | Software package for PC-based automation solutions, PC WORX BASIC license, contains all 5 IEC languages, without MSFC compiler, max. 256 byte input and output data, version-specific license key |
| 2985725 | PC WORX DEMO | Software package for PC-based automation solutions, PC WORX DEMO, contains all 5 IEC languages, with MSFC compiler, max. 16 bytes input and output data |
| 2985385 | PC WORX PRO LIC | Software package for PC-based automation solutions, PC WORX PRO license, contains all 5 IEC languages, with MSFC compiler, max. 128 kB input and output data, version-specific license key |
| 2985495 | PC WORX PRO-MSFC LIC | Software package for PC-based automation solutions, PC WORX PRO-MSFC license, contains all 5 IEC languages and MSFC compiler, max. 64 Kbytes IN, 64 Kbytes OUT, version-specific license key |

FAQs

- **Can I store the IP address of my controller permanently on the parameterization memory (IBS MC FLASH ...)?**

Can I store the IP address of my controller permanently on the parameterization memory (IBS MC FLASH ...)?

- **Is it admissible to use a bit function of a library as first command in a POE?**

Every POE needs a defined entry data type. The command in the first line changes the data type according to the respective command. In the case of a function from a library, the data type cannot be recognized during compilation and the ANY_NUM data type will be assumed erroneously, whereas the function is actually an ANY_BIT function. When downloading such a program, the device firmware 4.6 recognizes the different data type and aborts the download. You can avoid this download abort by inserting a valid command or a dummy in the first line which does not have access to the bit function of the library, e.g.: DUMMY:=DUMMY.

- **Is it possible to implement a bus parameterization with isolated disconnection if an incorrect bus is connected?**

Yes, it is possible. Before a bus start it however is necessary to activate the configuration frame. Activate configuration frame: Code: 0711 Parameter_Count: 0001 Frame_Reference: 0001 Start bus: Code: 0701

- **Why can't I use the RS-232 (PRG) of the Remote Field Controller 430/450 with PC WORX 3.03?**

A faulty communication DLL was supplied with PC WORX program version 3.03. When the RS-232 (PRG) is used for programming or for download, the control dialog reports a timeout. However, this is not case when using the Ethernet interface. Other control systems are likewise not affected. The error will be corrected for the next program version of PC WORX. As a remedy, please either use the Ethernet interface or copy the DLL (see attachment) into the following directory: ...\\pcworx3\\mwt. You can then use the serial interface as usual.

Address

PHOENIX CONTACT Deutschland GmbH
Flachmarktstr. 8
32825 Blomberg, Germany
Phone +49 5235 3 12000
Fax +49 5235 3 41200
<http://www.phoenixcontact.de>



© 2011 Phoenix Contact
Technical modifications reserved;

Компания «Life Electronics» занимается поставками электронных компонентов импортного и отечественного производства от производителей и со складов крупных дистрибьюторов Европы, Америки и Азии.

С конца 2013 года компания активно расширяет линейку поставок компонентов по направлению коаксиальный кабель, кварцевые генераторы и конденсаторы (керамические, пленочные, электролитические), за счёт заключения дистрибьюторских договоров

Мы предлагаем:

- Конкурентоспособные цены и скидки постоянным клиентам.
- Специальные условия для постоянных клиентов.
- Подбор аналогов.
- Поставку компонентов в любых объемах, удовлетворяющих вашим потребностям.
- Приемлемые сроки поставки, возможна ускоренная поставка.
- Доставку товара в любую точку России и стран СНГ.
- Комплексную поставку.
- Работу по проектам и поставку образцов.
- Формирование склада под заказчика.
- Сертификаты соответствия на поставляемую продукцию (по желанию клиента).
- Тестирование поставляемой продукции.
- Поставку компонентов, требующих военную и космическую приемку.
- Входной контроль качества.
- Наличие сертификата ISO.

В составе нашей компании организован Конструкторский отдел, призванный помогать разработчикам, и инженерам.

Конструкторский отдел помогает осуществить:

- Регистрацию проекта у производителя компонентов.
- Техническую поддержку проекта.
- Защиту от снятия компонента с производства.
- Оценку стоимости проекта по компонентам.
- Изготовление тестовой платы монтаж и пусконаладочные работы.



Тел: +7 (812) 336 43 04 (многоканальный)
Email: org@lifeelectronics.ru