CSM\_A3S\_DS\_E\_6\_1

## **Pushbutton Switch Series with Square 40-mm Body**

- Combines miniature design with distinct but soft sense of operation.
- Easy panel mounting from the front and simple lamp replacement without tools.



Refer to Safety Precautions for All Pushbutton Switches and Safety Precautions on page 18.

### **List of Models**

### **Lighted Pushbutton Switches**

A	Model	
Rectangular		A3SJ
Square		A3SA

■ Specifications: Refer to page 12.


■ Accessories: Refer to pages 10 to 11.

■ Dimensions: Refer to page 14.

OMRON

### **Model Number Structure**

Model Number Legend ..... The model numbers used to order sets are illustrated below. One set comprises the Operation Unit, Lamp, and Socket Unit. For information on combinations, refer to Ordering Information on pages 3 to 4.



### (1) Shape of **Operation Unit**

Sym- bol	Shape
J	Rectan- gular
Α	Square

### (2) Switch Specifications Standard Load

Symbol	Operation		
Α	Momentary	SPDT	
В	Alternate		
С	Momentary	DPDT	
D	Alternate	וטרטו	

### **Microload**

	Symbol	Operation		
	<ul><li>E Momentary</li><li>F Alternate</li></ul>		SPDT	
			31 01	
	G	Momentary	DPDT	
	Н	Alternate	וטוטו	

- Standard Load 250 VAC, 2 A 125 VDC, 0.4 A
- Microload 125 VAC, 0.1 A 30 VDC, 0.1 A

Minimum applicable load 5 VDC, 1 mA

- Momentary operation ...Self-resetting
- Alternate operation ...Self-holding

### (3) Screen Pattern Illumination-only models

Symbol	Screen pattern
	Single screen
1	
	Vertical 2-split screen
3	
	(rectangular models only)
	s with colored illumination

- can be ordered individually. Refer to page 5 for details.
- Colored Illumination



The built-in LED is colored.

### (4) Lighting Method - (5) Operation Unit Color **LED-lighted Models**

Symbol	Rated voltage
05E	5 VDC
12E	12 VDC
24E	24 VDC

### Incandescent **Lamp-lighted Models**

Symbol	voltage	
06	6 VAC/VDC	
14	14 VAC/VDC	
28	28 VAC/VDC	

## For LED

Symbol	Color
R	Red
Υ	Yellow
G	Green
W	White *

### Incandescent **Lamp-lighted Models**

Symbol	Color
R	Red
Υ	Yellow
G	Green
Α	Blue
W	White *

<sup>\*</sup> The color cap is transparent.

### Number of Built-in LEDs and Incandescent Lamps

Model Screen pattern		LED	Incandescent lamp
	Single screen	2	1
A3SJ	Vertical 2-split screen	2	2
A3SA	Single screen	1	1

### Structure of Split-screen Operation Unit **Type** Color cap Legend plate \* Dispersion plate Light-separation plate (2-split screen only) Vertical 2-split screen Single screen LED/incandescent (Rectangular models (Rectangular models only) lamp holder and square models) A3SJ Not included for the Square Models (A3SA) with incandescent lamp.

Ordering as a Set ......The model numbers used to order sets of Units are given in the following tables. One set comprises the Operation Unit, Lamp, and Socket Unit.

### **Standard Loads**



Single screen

Vertical 2-split screen

2

### Single screen

	Contact type Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		Operation Unit		
Output	Lighting	Operation	Momentary operation (Self-resetting)	Alternate operation (Self-holding)	color symbol
		5 VDC	A3SJ-90A1-05E□	A3SJ-90B1-05E□	
	LED	12 VDC	A3SJ-90A1-12E□	A3SJ-90B1-12E□	
SPDT		24 VDC	A3SJ-90A1-24E□	A3SJ-90B1-24E□	Enter the desired color
SPDI	In condessent	6 VAC/VDC	A3SJ-90A1-06□	A3SJ-90B1-06□	symbol for the Pushbutton
	Incandescent lamp	14 VAC/VDC	A3SJ-90A1-14□	A3SJ-90B1-14□	in $\square$ .
	lallip	28 VAC/VDC	A3SJ-90A1-28□	A3SJ-90B1-28□	R (Red)
		5 VDC	A3SJ-90C1-05E□	A3SJ-90D1-05E□	Y (Yellow)
	LED	12 VDC	A3SJ-90C1-12E□	A3SJ-90D1-12E□	G (Green)
DPDT		24 VDC	A3SJ-90C1-24E□	A3SJ-90D1-24E□	A (Blue) * W (White)
		6 VAC/VDC	A3SJ-90C1-06□	A3SJ-90D1-06□	vv (vviite)
	Incandescent lamp	14 VAC/VDC	A3SJ-90C1-14□	A3SJ-90D1-14□	
	lallip	28 VAC/VDC	A3SJ-90C1-28□	A3SJ-90D1-28□	

<sup>\*</sup> Incandescent lamp only.

### Vertical 2-split screen

		Contact type	Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		Operation Unit
Output	Lighting	Operation	Momentary operation (Self-resetting)	Alternate operation (Self-holding)	color symbol
SPDT	LED	24 VDC	A3SJ-90A3-24E□□	A3SJ-90B3-24E□□	Enter the desired color symbol for the Pushbutton
SFDT	Incandescent lamp	28 VDC	A3SJ-90A3-28□□	A3SJ-90B3-28□□	in □□. R (Red) Y (Yellow) G (Green)
DPDT	LED	24 VDC	A3SJ-90C3-24E□□	A3SJ-90D3-24E□□	
DFD1	Incandescent lamp	28 VDC	A3SJ-90C3-28□□	A3SJ-90D3-28□□	W (White) A (Blue) *

<sup>\*</sup> Incandescent lamp only.

### **Microloads**

Single screen

Contact type			Contact type Microload (125 VAC, 0.1 A; 30 VDC 0.1 A)		
Output	Operation Output Lighting		Momentary operation (Self-resetting)	Unit color symbol	
		5 VDC	A3SJ-90E1-05E□		
	LED	12 VDC	A3SJ-90E1-12E□	Enter the	
SPDT		24 VDC A3SJ-90E1-24E□		desired col-	
SFDT	Incan-	6 VAC/VDC	A3SJ-90E1-06□	or symbol	
	descent	14 VAC/VDC	A3SJ-90E1-14□	for the	
	lamp	28 VAC/VDC	A3SJ-90E1-28□	Pushbutton in $\square$ .	
		5 VDC	A3SJ-90G1-05E□	R (Red)	
	LED	12 VDC	A3SJ-90G1-12E□	Y (Yellow)	
DPDT		24 VDC	A3SJ-90G1-24E□	G (Green)	
	Incan-	6 VAC/VDC	A3SJ-90G1-06□	A (Blue) *	
	descent	14 VAC/VDC	A3SJ-90G1-14□	W (White)	
	lamp	28 VAC/VDC	A3SJ-90G1-28 🗆		

Individual models: Refer to pages 6 to 9.

(The Pushbutton, Lamp, and Switch can be ordered separately.)

Vertical 2-split screen

C	Contact type Operation Output Lighting			Microload (125 VAC, 0.1 A; 30 VDC 0.1 A) Momentary operation (Self-resetting)	Operation Unit color symbol
9	SPDT	LED	24 VDC	A3SJ-90E3-24E□□	Enter the desired col-
	SPDT	Incan- descent lamp	28 VDC	A3SJ-90E3-28□□	or symbol for the Pushbutton in $\square\square$
	OPDT	LED	24 VDC	A3SJ-90G3-24E□□	R (Red) Y (Yellow) G (Green)
	)F () 1	Incan- descent lamp	28 VDC	A3SJ-90G3-28□□	W (White) A (Blue) *

<sup>\*</sup> Incandescent lamp only.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Ordering as a Set ...... The model numbers used to order sets of Units are given in the following tables. One set comprises the Operation Unit, Lamp, and Socket Unit.

**Standard Loads** 



Single screen

Single screen

Contact type Operation Output Lighting		Standard load (250 VA	Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		
		Momentary operation (Self-resetting)	Alternate operation (Self-holding)	Operation Unit color symbol	
		5 VDC	A3SA-90A1-05E□	A3SA-90B1-05E□	
	LED	12 VDC	A3SA-90A1-12E□	A3SA-90B1-12E□	
SPDT		24 VDC	A3SA-90A1-24E□	A3SA-90B1-24E□	
SPDI	Incandescent lamp	6 VAC/VDC	A3SA-90A1-06□	A3SA-90B1-06□	Enter the desired color
		14 VAC/VDC	A3SA-90A1-14□	A3SA-90B1-14□	symbol for the Pushbutton in □.
		28 VAC/VDC	A3SA-90A1-28□	A3SA-90B1-28□	R (Red)
		5 VDC	A3SA-90C1-05E□	A3SA-90D1-05E□	Y (Yellow)
	LED	12 VDC	A3SA-90C1-12E□	A3SA-90D1-12E□	G (Green) A (Blue) *
DPDT	24 VDC	A3SA-90C1-24E□	A3SA-90D1-24E□	W (White)	
	6 VAC/VDC	A3SA-90C1-06□	A3SA-90D1-06□		
	Incandescent lamp	14 VAC/VDC	A3SA-90C1-14□	A3SA-90D1-14□	
	lamp	28 VAC/VDC	A3SA-90C1-28□	A3SA-90D1-28□	

<sup>\*</sup> Incandescent lamp only.

### Microloads

Single screen

L. C.			Microload (125 VAC, 0.1 A; 30 VDC 0.1 A) Momentary operation	Operation Unit color symbol
Output	Operation tput Lighting		(Self-resetting)	color symbol
		5 VDC	A3SA-90E1-05E□	
	LED	12 VDC	A3SA-90E1-12E□	
SPDT		24 VDC	A3SA-90E1-24E□	
SPDI	Incandescent lamp	6 VAC/VDC	A3SA-90E1-06□	Enter the desired color
		14 VAC/VDC	A3SA-90E1-14□	symbol for the Pushbutton in $\square$ .
		28 VAC/VDC	A3SA-90E1-28□	R (Red)
		5 VDC	A3SA-90G1-05E□	Y (Yellow)
	LED DPDT	12 VDC	A3SA-90G1-12E□	G (Green) A (Blue) *
DRDT		24 VDC	A3SA-90G1-24E□	W (White)
2.2.		6 VAC/VDC	A3SA-90G1-06□	(
	Incandescent lamp	14 VAC/VDC	A3SA-90G1-14□	
	шпр	28 VAC/VDC	A3SA-90G1-28□	

<sup>\*</sup> Incandescent lamp only.

Individual models: Refer to pages 6 to 9.


(The Pushbutton, Lamp, and Switch can be ordered separately.)

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

### Illumination-only and Colored-illumination LED Models


Illumination only describes LED models for which the screen color is the same whether the LED is lit or not. The screen simply becomes brighter when the LED lights.

Example: Red LED



Colored illumination describes LED models for which the screen color is white when the LED is not lit and changes to the color of the LED lamp when the LED is lit.

Example: Red LED




Dis	play (Operation Un	it)	LED	Socket Unit	
Single screen	Rectangular models A3SJ-5801				
	Square models	A3SA-5801	Select the LED lamps to suit your desired	Select from the Switches on	
2-split screen	Rectangular models only	A3SJ-5921	coloration from the selection on page 9.	page 9.	

OMRON

Ordering Individually ....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

Ordering ...... Specify a model number from the following page.



Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Ordering Individually ....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

### **Operation Unit LED-lighted Models**

(LED is not built in.)

	Appearance Rectangular Models Square Models					
	Appoulation			(2 LEDs)	(1 LED)	
				(transparent legend	(transparent legend	
Sc	creen patteri	n	Display color	plate built in)	plate built in)	
			White	A3SJ-5801	A3SA-5801	
Single s	ecroon		Red	A3SJ-5802	A3SA-5802	
Siligie	Scieen		Green	A3SJ-5803	A3SA-5803	
			Yellow	A3SJ-5805	A3SA-5805	
			White/red	A3SJ-5901		
			White/green	A3SJ-5902		
	Standard		White/yellow	A3SJ-5904	-	
	split screen		Red/green	A3SJ-5905		
			Red/yellow	A3SJ-5907		
			Green/yellow	A3SJ-5909		
			Red/white	A3SJ-5911		
2-split	_		Green/white	A3SJ-5912		
screen *	Reverse split		Yellow/white	A3SJ-5914		
	screen		Green/red	A3SJ-5915	_	
			Yellow/red	A3SJ-5917		
			Yellow/green	A3SJ-5919		
			White/white	A3SJ-5921		
	One-color					
			Red/red	A3SJ-5922		
	One-color 2-split screen		Red/red Green/green	A3SJ-5922 A3SJ-5923	_	

Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Note: The color cap is transparent when the display color is white.

\* Two-split screen configurations are given with the OMRON surface of the case downward.

Ordering Individually....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

### **Operation Unit**

### **Incandescent Lamp-lighted Models**

(Incandescent lamp is not built in.)

(incandesc	Appearance Rectangular Square					
				(transparent legend	(Legend plate not	
	Screen patte	1	Display color	plate built in)	included)	
		One lamp	White	A3SJ-5301	A3SA-5301	
			Red	A3SJ-5302	A3SA-5302	
			Green	A3SJ-5303	A3SA-5303	
			Blue	A3SJ-5304	A3SA-5304	
Single	e screen		Yellow	A3SJ-5305	A3SA-5305	
Jg.		Two lamps	White	A3SJ-5321		
			Red	A3SJ-5322		
			Green	A3SJ-5323	_	
			Blue	A3SJ-5324		
			Yellow	A3SJ-5325		
			White/red	A3SJ-5201		
			White/green	A3SJ-5202		
			White/blue	A3SJ-5203		
_			White/yellow	A3SJ-5204		
	Standard split		Red/green	A3SJ-5205		
	screen		Red/blue	A3SJ-5206	_	
			Red/yellow	A3SJ-5207		
			Green/blue	A3SJ-5208		
			Green/yellow	A3SJ-5209		
			Blue/yellow	A3SJ-5210		
			Red/white	A3SJ-5211		
0!!!			Green/white	A3SJ-5212	-	
2-split screen *		Holol	Blue/white	A3SJ-5213		
3010011	_		Yellow/white	A3SJ-5214		
	Reverse		Green/red	A3SJ-5215	=	
	split screen		Blue/red	A3SJ-5216	_	
	30.00		Yellow/red	A3SJ-5217	=	
			Blue/green	A3SJ-5218	=	
			Yellow/green	A3SJ-5219		
			Yellow/blue	A3SJ-5220		
			White/white	A3SJ-5221		
	One-color		Red/red	A3SJ-5222		
	2-split		Green/green	A3SJ-5223	_	
	screen		Blue/blue	A3SJ-5224	-	
			Yellow/yellow	A3SJ-5225	-	
			diamlass aplas ia subi			

Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Note: The color cap is transparent when the display color is white.

\* Two-split screen configurations are given with the OMRON surface of the case downward.

Ordering Individually ....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

### Lamp

### **LED Lamp**

Operating voltage	5 VDC	12 VDC	24 VDC
Color	Model (DC only)	Model (DC only)	Model (DC only)
Red	SLL-05ER	SLL-12ER	SLL-24ER
Yellow	SLL-05EY	SLL-12EY	SLL-24EY
Green	SLL-05EG	SLL-12EG	SLL-24EG
White	SLL-05EW	SLL-12EW	SLL-24EW

Note: The A3SJ (M2SJ) requires two LEDs for each Switch. The A3SA (M2SA) requires one LED.

### **Incandescent Lamp**

Lamp type Operating voltage	Standard lamp	Low-voltage lamp
5 VAC/VDC	SLL-06	SLL-06H
12 VAC/VDC	SLL-14	SLL-14H
24 VAC/VDC	SLL-28	SLL-28H

Note: The low-voltage lamp has an advantage in that it generates less heat.

Switch (common to both LED models and incandescent lamp-lighted models)

Cont	act type	Number of outputs	Appearance Operation	Rectangular models	Square models	Selection precautions
		1	Momentary operation	A3SJ-8010	A3SA-7010	Use the Socket Unit in
Stan-	Standard load Silver contacts	•	Alternate operation	A3SJ-8020	A3SA-7020	combination with the same shape Operation Unit
		_	Momentary operation	A3SJ-8030	A3SA-7030	(rectangular or square). Example:
			Alternate operation	A3SJ-8040	A3SA-7040	For the A3SJ-5801 Rectan- gular Operation Unit, select
		Momentary operation		A3SJ-8050	A3SA-7050	the A3SJ-8□□0
Micro-	allov	Alternate operation	A3SJ-8060	A3SA-7060	Socket Unit.  Momentary operation is	
load		Momentary operation	A3SJ-8070	A3SA-7070	self-resetting, and alternate operation is self-holding (i.e.,	
		2	Alternate operation	A3SJ-8080	A3SA-7080	push-on, push-off).

## Accessories, Replacements, and Tools

**Accessories for Rectangular Models** 

Name	Appearance	Classification	Model	Application precautions
		Short edge Barriers (1 pair)	A3SA-4001	The survey of a Powisi is to survey and surelf-undication in
Barrier	4646	Short intermediate Barriers	A3SA-4002	The purpose of a Barrier is to prevent malfunctioning and to improve design image of the mounting panel.  There is one intermediate Barrier and one pair of
Damei	MAMA	Long edge Barriers (1 pair)	A3SJ-4003	edge Barriers (2 Barriers).  Mount Short Barriers horizontally.  Mount Long Barriers vertically.
		Long intermediate Barriers	A3SJ-4004	Mount Long Barriers vertically.
Switch Guard		-	A3SJ-5050	Cannot be used with Barrier or Seal Cover.
Seal Cover		-	A3SJ-5060	Cannot be used with Barrier or Switch Guard.     Cap material: Vinyl chloride
Long Mounting Plate		1 pair	A3SJ-3002	Use when vertically mounting individual (with Barrier) or multiple Switches (in standard mounting style and with Barrier). A Short Mounting Plate is attached to the Switch; replace it with the long one.

### **Accessories for Square Models**

Name	Appearance	Classification	Model	Application precautions
Barrier		Short Edge Barriers (1 pair) A3SA-4001		The purpose of the Barrier is to prevent malfunctioning and to improve design image of the mounting
barrier	Short Intermediate Barrier	A3SA-4002	panel.	
Switch Guard		-	A3SA-5050	Cannot be used with Barrier or Seal Cover.
Seal Cover		_	A3SA-5060	Cannot be used with Barrier or Switch Guard.     Cap material: Vinyl chloride

■ Accessory mounting: Refer to page 19.

# Accessories, Replacements, and Tools Replacements for Rectangular Models

Name	Appearance	Classification		Model	Application precautions
		Wire-wrap terminals		A3SJ-4104	
Socket		PCB terminals		A3SJ-4105	Sockets cannot be used for multiple mounting.
	1 1/11/11	Solder terminals		A3SJ-4106	
Dispersion plate		Milk-white	Single screen	A3SJ-5107	-
		Transparent		A3SJ-5600	
		White	Single screen	A3SJ-5601	
		Red		A3SJ-5602	
		Green		A3SJ-5603	
		Blue		A3SJ-5604	Contact your OMRON representative for color
0-1		Yellow		A3SJ-5605	changes or inscribing.
Color cap		Transparent		A3SJ-5630	If LEDs are to be used, use a color cap that matches the LED color.
	~	White	1	A3SJ-5631	The blue color cap is only for incandescent lamps.
	1	Red	0 17	A3SJ-5632	
		Green	2-split screen	A3SJ-5633	
		Blue		A3SJ-5634	
	7	Yellow		A3SJ-5635	
Logand plata		Transparent		A3SJ-4204	A transparent legend plate is mounted on the
Legend plate		Milk-white		A3SJ-4203	Operation Unit.

### **Replacements for Square Models**

Name	Appearance	Classification	Model	Application precautions
		Wire-wrap terminals	A3SA-4101	
Socket		PCB terminals	A3SA-4102	Sockets cannot be used for multiple mounting.
		Solder terminals	A3SA-4103	
Dispersion plate		Milk-white	A3SA-5107	-
		Transparent	A3SA-5600	
		White	A3SA-5601	Contact your OMRON representative for color
Color cap	/IEI	Red	A3SA-5602	changes or inscribing.
Color cap		Green	A3SA-5603	If LED colors are to be used, use a color cap that
	V	Blue	A3SA-5604	matches the LED color.
	Yellow	A3SA-5605		
Legend plate		Transparent	A3SA-4204	A transparent color cap is mounted to a standard Display. Legend plates cannot be used, however,
Logoria piate		Milk-white	A3SA-4203	with Displays for incandescent lamps.

### Tools

Name	Appearance	Classification	Model	Application precautions
Extractor		-	A3PJ-5080	Convenient for extracting the Operation Unit.

■ Accessory mounting: Refer to page 19.

OMRON 1

## **Specifications**

### **Approved Standard Ratings** UL (File No. E41515), CSA (File No. LR45258)

3 A at 125 VAC Standard Load: 2 A at 250 VAC Microload: 0.1 A at 125 VAC 0.1 A at 30 VDC

Note: Certification has been obtained for the Switch Unit.

For detailed information on individual products that have received

certification, consult your supplier.

### Ratings For Standard Loads

	Non-	induct	ive loa	ive load (A)		Inductive load (A)		
Rated voltage	Resistive load		Lamp	load		ctive ad	Moto	r load
	NC	NO	NC	NO	NC	NO	NC	NO
125 VAC 250 VAC	3	-	1 0.7	0.7 0.5		2 .5	1.5 1	1 0.7
8 VDC 14 VDC	3 3			1		2 .5		.5 .5
30 VDC 125 VDC 250 VDC	0.4 0.2		_	1 05 03	0	.5 .4 .2	-	1 05 03

- Note: 1. The above values are for steady-state currents. 2. Inductive load: Power factor = 0.4; time constant = 7 ms.
  - 3. The lamp load has an inrush current of 10 times the steady-state
  - 4. The motor load has an inrush current of 6 times the steady-state current.

The rated values are for testing conducted under the following conditions.

(1) Ambient temperature: 20±2°C

(2) Ambient humidity: 65% ±5%RH

(3) Operating frequency: 20 times/min

### For Microloads

	0.1 A at 30 VDC (resistive load); 0.1 A at 125 VAC (resistive load)
Minimum applicable load	1 mA at 5 VDC

### **LED Lamp**

Туре	Applied voltage	Rated voltage	Rated current	Built-in limiting resistance
	5 VDC±5%	5 VDC	30 mA	39 Ω
DC only	12 VDC±5%	12 VDC	15 mA	270 Ω
	24 VDC±5%	24 VDC	12.5 mA	1300 Ω

### **Incandescent Lamp**

Applied voltage	Rated voltage	Standard lamp	Low-power lamp
Voltage		Rated current	Rated current
5 VAC/VDC	6 VAC/VDC	200 mA	100 mA
12 VAC/VDC	14 VAC/VDC	80 mA	40 mA
24 VAC/VDC	28 VAC/VDC	40 mA	25 mA

### **Characteristics**

Operating	Mechanical	Momentary operation models: 120 operations/min max. *1		
frequency	Electrical	20 operations/min max.		
Inculation	n resistance	100 MΩ min. (at 500 VDC)		
ilisulatioi	,	100 Ms2 min. (at 500 VDC)		
	Between terminals of same polarity	1,000 VAC, 50/60 Hz for 1 minute		
	Between terminals of different polarity	2,000 VAC, 50/60 Hz for 1 minute		
Dielectric strength	Between current- carrying metal part and ground	2,000 VAC, 50/60 Hz for 1 minute		
	Between each terminal and non-current-carry- ing metal part	2,000 VAC, 50/60 Hz for 1 minute		
	Between lamp terminals	1,000 VAC, 50/60 Hz for 1 minute *2		
Vibration resistance	Malfunction	10 to 55 Hz, 1.5-mm double amplitude (1 ms max.)		
Shock	Destruction	500 m/s <sup>2</sup> max.		
resistance Malfunction		200 m/s <sup>2</sup> max. (1 ms max.)		
Life expect-	Mechanical	Momentary operation models: 1,000,000 operations min. Alternate operation models: 100,000 operations min. (One operation consists of set and reset operations.)		
	Electrical	100,000 operations min. (rated load)		
Weight		Approx. 10 g		
Inrush	NC	Standard load: 10 A max.		
current	NO	Standard load: 10 A max.		
Ambient temperat	operating ure	−10 to 50°C (with no icing or condensation)		
Ambient operating humidity		35% to 85% RH		
Ambient storage temperature		−25 to 65°C (with no icing or condensation)		
_	f protection	IP00		
class	hock protection	Class II		
PTI (proo	f tracking index)	175		
Pollution	degree	3 (IEC 60947-5-1)		

<sup>\*1.</sup> With alternate operation models, 60 operations/min max. One operation cycle consists of set and reset operations.

### **Operating Characteristics**

Operating characteristics	Operation	Momentary operation models	Alternate operation models
Operating force	OF max.	3.92 N	4.90 N
Releasing force	RF min.	0.49 N	0.294 N
Total travel	TT	Approx. 3 mm	Approx. 3 mm
Pretravel	PT max.	2.2 mm	2.2 mm
Lock travel alternate	LTA min.	-	0.5 mm


### **Contact Form**

Name	Contact Form
Double-throw contacts	COM NO


<sup>\*2.</sup> With no incandescent lamp or LED lamp mounted.

### **Nomenclature**

## **Model Structure Operation Unit Structure**




OMRON 1



Note: Unless specified, a tolerance of ±0.4 mm applies for all dimensions. Use a mounting panel thickness of 1 to 4 mm.

### **Terminal Arrangement**


Bottom View (All are shown with the OMRON logo facing down.)




Note: The arrangements given above are not indicated on the Socket Unit.

### Contact Type

Incandescent Lamp-lighted Models (The terminal arrangements are the same as for the LED-lighted models.)



### **LED Lamp-lighted Models**




**Dimensions** (Unit: mm)

### **Panel Cutout** (If using a Switch Guard or Seal Cover, refer to the panel cutout diagrams on page 17.) **Rectangular Models (A3SJ)**

Cla	ssification	Mounting design	Panel cutout	Remarks
	Individual mounting, horizontal	17.8±0.2 + 24±0.2 +	16.2±0.2	Panel cutout spacing between rows of Units:
Flores	Multiple mounting, horizontal	17.8±0.2 1 2 n	16.2±0.2 + 24n-1.6±0.2 -	→ <del>    -</del> 3 min.
Flange mount models	Individual mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2	6 min.
	Multiple mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2 17.8n-1.6±0.2	
	Individual mounting, horizontal	19.8	16.2±0.2	Panel cutout spacing between rows of Units:
Barrier	Multiple mounting, horizontal	19.8 1 2 n	16.2±0.2 25.3n+1.6±0.2	1.4 <del></del>
mount models	Individual mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2 20.7±0.2	# 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
	Multiple mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2 19.1n+1.6±0.2	Dotted line indicates the position of each mounting Barrier.

<sup>\*</sup> If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

### Square Models (A3SA)




 $<sup>^{\</sup>star}$  If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

**Dimensions** (Unit: mm)

### **Accessory Mounting Dimensions**


### Legend Plate Rectangular Models A3SJ-4203/-4204



### Square Models A3SA-4203/-4204




# Extractor A3PJ-5080




# Socket-mounting Dimensions Rectangular Models


# Wire-wrap Terminals A3SJ-4104



### Solder Terminals A3SJ-4106



# PCB Terminals A3SJ-4105




-21.2-

### **Terminal Hole Dimensions**



## PCB Cutout (Bottom View)




**Dimensions** (Unit: mm)


### **Square Models**

## **Wire-wrap Terminals Solder Terminals PCB Terminals** A3SA-4101 A3SA-4103 A3SA-4102 -212 17.6 -15 8.2 15.7±0 0.5-11 -3.6 **PCB Cutout Terminal Hole Dimensions** (bottom view) Eight, 1.5-dia. holes The OMRON logo is downward on the Socket Unit.

### **Switch and Guard Mounting Dimensions**



### **Seal Cover Mounting Dimensions**



Note: 1. Recommended panel thickness: 1.0 to 3.3 mm

2. Unless otherwise specified, a tolerance of ±0.4 mm applies to all dimensions.

### **Safety Precautions**

### Refer to Safety Precautions for All Pushbutton Switches.

### Precautions for Correct Use

#### Mounting

 Always make sure that the power is turned OFF before mounting, removing, or wiring the Switch, or performing maintenance. Electric shock or fire may occur.

### Wiring

- For wiring, use a wire size that is appropriate for the applied voltage and the supplied current. Be sure to perform soldering according to the following conditions. Using the Switch with incomplete soldering may result in errors and heat, which may cause fire.
- (1) Manual soldering: Use a soldering iron with a tip temperature of 350°C maximum and complete soldering within 3 seconds.
- (2) Dip soldering: Solder at 350°C for 3 s or less.

Wait for one minute after soldering before exerting any external force on the solder

- Use non-corrosive liquid rosin as the flux.
- If screw-tightened terminals are used, hold the Socket Unit Set or Socket Unit and install the lead wiring applying a torque of less than 0.98 N·m to the Socket Unit. Applying a torque of more than 0.98 N·m may result in damage. The tightening torque is 0.59 to 0.78 N·m.
- Make sure that the insulating sheath of the wires does not come in contact with the Unit. If wiring is performed with the insulating sheath of the wires coming in contact with the Unit, use wire with a minimum heat resistance of 100°C.
- After wiring the Switch, make sure that there is a suitable isolation distance.

### **Operating Environment**


 Do not use in locations that are subject to dust, oil, or metal fillings, because these may penetrate the interior the Switch and cause malfunction.

### **Using Microloads**

• Using a standard load switch when a microload circuit is opened or closed may cause wear on the contacts. Use the switch within the operating range. (Refer to the diagram below.) Even when using microload models within the operating range shown below, if inrush current occurs when the contacts are opened or closed, it may cause the contact surface to become rough, and so decrease life expectancy. Therefore, insert a contact protection circuit where necessary.

The minimum applicable load is the N-level reference value. This value indicates the malfunction reference level for the reliability level of 60% ( $\lambda$  60) (conforming to JIS C5003).

The equation  $\lambda$  60 = 0.5 x 10<sup>-4</sup>/time indicates that the estimated malfunction rate is less than 1/2,000,000 with a reliability level of 60%.



### **LED Lamp**

 A current-limiting resistor for the LED lamp is built in, so no external resistor is required.

Rated voltage	Built-in limiting resistance
5 VDC	39 Ω
12 VDC	270 Ω
24 VDC	1300 Ω

### **Incandescent Lamp**

 It is advantageous in terms of service life and heat generation to apply 80% of the rated voltage (operating voltage) to the incandescent lamp.

#### Operation

 Always mount the Operation Unit before operating the Switch.
 (Using your fingers or tweezers to operate moving parts of the Switch may deform internal parts and cause malfunctions.)

#### **Character Film**

• If the character film is to be specially prepared, use heat-resistant film with a maximum thickness of 0.2 mm.



#### Others

• If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

### **Application**


### Replacing Incandescent and LED Lamps and Panel Mounting

### Removing the Display

- Grasp the groove on the color cap surface, and pull it firmly toward you to remove the Display.
- An Extractor (A3PJ-5080) is available to conveniently remove the Display.




### Mounting and Replacing Incandescent and LED Lamps




### Inserting the Display into the Socket Unit

Insert the Operation Unit in the proper direction. With the OMRON logo downward, insert the Operation Unit so that the lamp/LED terminals on the inside surface of the Unit case and the contactors of the Display.



### Rated Voltage and Color of LED


The LED voltage rating is indicated on the base. Use the LED within  $\pm 5\%$  of voltage range.



### Mounting to the Switch Panel


Mount the Socket Unit to the panel by inserting it from the front of the panel.

Mount the Socket Unit so that the OMRON logo is downward.



### **Barrier Mounting**

- Place the Edge Barrier on the side of the Socket Unit, and then insert it into the panel.
- Insert the Intermediate Barrier between the Switches after inserting the Socket Units into the panel.



## Inscribing Legend Plate Characters Inscribing

A3SJ (M2SJ)

- Inscription depth: 0.5 mm max.
- The legend plate is made of polycarbonate, so apply an alcoholbased paint coating, such as melamine, phthalate, or acrylic resin paint when marking the legend.




Legend plate

 When replacing the legend plate, be careful that the coil spring in the Display does not become removed.

## Assembling the Legend Plate (Plunger) A3SA (M2SA)

(LED Lamp)

(1) Assemble the color plate to the plunger, and then assemble the legend plate on top.



(Incandescent Lamp)

(2) Inscribe the surface of the plunger, and then coat the surface.

### Lighted Square Pushbutton Switches


Assemble models A3SA-5301 to A3SA-5305 so that the hook is toward you.



Hook toward you

Note: Legend plates cannot be used with A3SA Displays for incandescent lamps.

(3) Assemble the color cap to the inscribed plunger.



(4) Push in the color in the direction of the arrow to assemble the plunger and the lamp holder.

### Lighted Square Pushbutton Switches

A3SA

Perform the assembly so that the wide groove and the hook on the plunger are in the same direction.



### Indicator

M2SA

Perform the assembly so that the wide groove and the hook on the plunger are in the same direction.



### Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

### Warranty and Limitations of Liability

#### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

### **Application Considerations**

#### SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

### **Disclaimers**

### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2010.10

In the interest of product improvement, specifications are subject to change without notice.





OOO «ЛайфЭлектроникс" "LifeElectronics" LLC

ИНН 7805602321 КПП 780501001 P/C 40702810122510004610 ФАКБ "АБСОЛЮТ БАНК" (ЗАО) в г.Санкт-Петербурге К/С 3010181090000000703 БИК 044030703

Компания «Life Electronics» занимается поставками электронных компонентов импортного и отечественного производства от производителей и со складов крупных дистрибьюторов Европы, Америки и Азии.

С конца 2013 года компания активно расширяет линейку поставок компонентов по направлению коаксиальный кабель, кварцевые генераторы и конденсаторы (керамические, пленочные, электролитические), за счёт заключения дистрибьюторских договоров

### Мы предлагаем:

- Конкурентоспособные цены и скидки постоянным клиентам.
- Специальные условия для постоянных клиентов.
- Подбор аналогов.
- Поставку компонентов в любых объемах, удовлетворяющих вашим потребностям.
- Приемлемые сроки поставки, возможна ускоренная поставка.
- Доставку товара в любую точку России и стран СНГ.
- Комплексную поставку.
- Работу по проектам и поставку образцов.
- Формирование склада под заказчика.
- Сертификаты соответствия на поставляемую продукцию (по желанию клиента).
- Тестирование поставляемой продукции.
- Поставку компонентов, требующих военную и космическую приемку.
- Входной контроль качества.
- Наличие сертификата ISO.

В составе нашей компании организован Конструкторский отдел, призванный помогать разработчикам, и инженерам.

Конструкторский отдел помогает осуществить:

- Регистрацию проекта у производителя компонентов.
- Техническую поддержку проекта.
- Защиту от снятия компонента с производства.
- Оценку стоимости проекта по компонентам.
- Изготовление тестовой платы монтаж и пусконаладочные работы.



Тел: +7 (812) 336 43 04 (многоканальный) Email: org@lifeelectronics.ru